

**Gaylord Community Schools
Early Childhood Center
Fixture Conversion Schedule**

Type of Area	Room Name	Type of Fixture	Replacement Product	# of Existing Fixtures or Devices	# of Replacement Fixtures or Devices	Fixture Conversion Plan	# of Replacement Lamps / Fixture	Total # of Lamps, Fixtures, or Devices
Classroom and Staff Rooms	Room 46	4' 2L 32W T8	1 x 4 LED 30W Panel Light	18	18	Replace existing fixture with a new 1 x 4 LED panel light.	1	18
Classroom and Staff Rooms	Room 45	4' 2L 32W T8	1 x 4 LED 30W Panel Light	17	17	Replace existing fixture with a new 1 x 4 LED panel light.	1	17
Classroom and Staff Rooms	Room 45 office	4' 2L 32W T8	4' 15W 4000K LED Linear Tube	1	1	Retrofit fixture. Replace existing fluorescent tubes with LED linear tubes on a one for one basis.	2	2
Classroom and Staff Rooms	Room 45	4' 2L 32W T8	1 x 4 LED 30W Panel Light	15	15	Replace existing fixture with a new 1 x 4 LED panel light.	1	15
Gymnasium	Gym 49B	300W Induction	120W 5000K LED Linear High Bay	9	6	Replace existing fixture with a new LED linear high bay.	1	6
Gymnasium	Gym 49B	4' 2L 32W T8	4' 15W 4000K LED Linear Tube	4	4	Retrofit fixture. Replace existing fluorescent tubes with LED linear tubes on a one for one basis.	2	8
Storage and Mechanical	Storage 49A	4' 2L 32W T8	4' 15W 4000K LED Linear Tube	2	2	Retrofit fixture. Replace existing fluorescent tubes with LED linear tubes on a one for one basis.	2	4
Classroom and Staff Rooms	Technology Room	4' 3L 32W T8	4' 15W 4000K LED Linear Tube	7	7	Retrofit fixture. Delamp fixture by removing the existing 3 fluorescent tubes and replacing them with 2 LED linear tubes.	2	14
Hallways	Hallways	4' 2L 32W T8	4' 15W 4000K LED Linear Tube	26	26	Retrofit fixture. Replace existing fluorescent tubes with LED linear tubes on a one for one basis.	2	52
Hallways	Hallways	4' 2L 32W T8	4' 15W 4000K LED Linear Tube	13	13	Retrofit fixture. Replace existing fluorescent tubes with LED linear tubes on a one for one basis.	2	26
Classroom and Staff Rooms	Room 53	4' 2L 32W T8	4' 15W 4000K LED Linear Tube	4	4	Retrofit fixture. Replace existing fluorescent tubes with LED linear tubes on a one for one basis.	2	8
Hallways	Hallways	4' 3L 32W T8	4' 15W 4000K LED Linear Tube	3	3	Retrofit fixture. Delamp fixture by removing the existing 3 fluorescent tubes and replacing them with 2 LED linear tubes.	2	6
Classroom and Staff Rooms	Room 41	4' 2L 32W T8	4' 15W 4000K LED Linear Tube	21	21	Retrofit fixture. Replace existing fluorescent tubes with LED linear tubes on a one for one basis.	2	42
Classroom and Staff Rooms	Room 41	4' 2L 32W T8	4' 15W 4000K LED Linear Tube	14	14	Retrofit fixture. Replace existing fluorescent tubes with LED linear tubes on a one for one basis.	2	28
Classroom and Staff Rooms	Room 40A	4' 3L 32W T8	4' 15W 4000K LED Linear Tube	12	12	Retrofit fixture. Delamp fixture by removing the existing 3 fluorescent tubes and replacing them with 2 LED linear tubes.	2	24
Classroom and Staff Rooms	Room 40A	4' 2L 32W T8	4' 15W 4000K LED Linear Tube	2	2	Retrofit fixture. Replace existing fluorescent tubes with LED linear tubes on a one for one basis.	2	4

**Gaylord Community Schools
Early Childhood Center
Fixture Conversion Schedule**

Type of Area	Room Name	Type of Fixture	Replacement Product	# of Existing Fixtures or Devices	# of Replacement Fixtures or Devices	Fixture Conversion Plan	# of Replacement Lamps / Fixture	Total # of Lamps, Fixtures, or Devices
Classroom and Staff Rooms	Room 40B	4' 3L 32W T8	4' 15W 4000K LED Linear Tube	13	13	Retrofit fixture. Delamp fixture by removing the existing 3 fluorescent tubes and replacing them with 2 LED linear tubes.	2	26
Classroom and Staff Rooms	Room 40B	4' 3L 32W T8 - EBB	4' 15W 4000K LED Linear Tube	2	2	Retrofit fixture. Delamp fixture by removing the existing 3 fluorescent tubes and replacing them with 2 LED linear tubes. Install a new LED tube emergency battery back-up power supply.	2	4
Classroom and Staff Rooms	Room 40B Storage	4' 2L 32W T8	4' 15W 4000K LED Linear Tube	5	5	Retrofit fixture. Replace existing fluorescent tubes with LED linear tubes on a one for one basis.	2	10
Classroom and Staff Rooms	Room 42B	4' 2L 32W T8	4' 15W 4000K LED Linear Tube	24	24	Retrofit fixture. Replace existing fluorescent tubes with LED linear tubes on a one for one basis.	2	48
Classroom and Staff Rooms	Room 42A	4' 2L 32W T8	4' 15W 4000K LED Linear Tube	19	19	Retrofit fixture. Replace existing fluorescent tubes with LED linear tubes on a one for one basis.	2	38
Classroom and Staff Rooms	Room 43	4' 2L 32W T8	4' 15W 4000K LED Linear Tube	16	16	Retrofit fixture. Replace existing fluorescent tubes with LED linear tubes on a one for one basis.	2	32
Classroom and Staff Rooms	Room 44	4' 2L 32W T8	4' 15W 4000K LED Linear Tube	18	18	Retrofit fixture. Replace existing fluorescent tubes with LED linear tubes on a one for one basis.	2	36
Bathrooms	Bathrooms	4' 2L 32W T8	4' 15W 4000K LED Linear Tube	8	8	Retrofit fixture. Replace existing fluorescent tubes with LED linear tubes on a one for one basis.	2	16
Classroom and Staff Rooms	Room 51B	4' 2L 32W T8	4' 15W 4000K LED Linear Tube	4	4	Retrofit fixture. Replace existing fluorescent tubes with LED linear tubes on a one for one basis.	2	8
Classroom and Staff Rooms	Room 52	4' 2L 32W T8	4' 15W 4000K LED Linear Tube	5	5	Retrofit fixture. Replace existing fluorescent tubes with LED linear tubes on a one for one basis.	2	10
Classroom and Staff Rooms	Room 51A	4' 2L 32W T8	4' 15W 4000K LED Linear Tube	4	4	Retrofit fixture. Replace existing fluorescent tubes with LED linear tubes on a one for one basis.	2	8
Bathrooms	Bathroom	4' 2L 32W T8	4' 15W 4000K LED Linear Tube	1	1	Retrofit fixture. Replace existing fluorescent tubes with LED linear tubes on a one for one basis.	2	2
				287	284			512